



SHEET NOTES

1. (E) 4.16/2.4KV, 3-PHASE TEMPORARY OVERHEAD DISTRIBUTION LINE.
2. (E) CAFS SUBSTATION.
3. (E) MANCAMP LOCATION.
4. CONTRACTOR TRAILERS.
5. PROPOSED 138KV GVEA TRANSMISSION LINE.
6. SECTIONALIZING SWITCH SS-15 FOR INTERRUPTION OF MANCAMP/LRDR CONSTRUCTION POWER SERVICE.
7. (E) DOUBLE ENDED POWER DISTRIBUTION POLE FOR EXTENSION OF OVERHEAD POWER TO CONTRACTOR LAYDOWN AREAS.
8. (E) DOUBLE ENDED POWER DISTRIBUTION POLE FOR EXTENSION OF SERVICE TO CONTRACTOR TRAILER AREA.
9. PROVIDE 4.16/2.4KV, 3-PHASE OVERHEAD (OR UNDERGROUND) TEMPORARY POWER EXTENSIONS (SEE SECTIONS 01 50 01.01 00) FROM EXISTING OVERHEAD DISTRIBUTION SYSTEM POLES FOR CONTRACTOR TRAILERS. CP1 CONSTRUCTION AND LAYDOWN POWER ALONG APPROXIMATE ROUTE SHOWN TO AVOID FUTURE ON-SITE CONSTRUCTION.
10. CONTRACTOR PROVIDED TEMPORARY POWER TO CONTRACTOR TRAILERS. INCLUDE EQUIVALENT OF 1 EA - 75KVA, 4.16KV PRIMARY, 120/240V SECONDARY, POLE OR PAD MOUNTED TRANSFORMER(S) FOR EACH 4 TRAILERS. CONTRACTOR TO PROVIDE PRIMARY AND SECONDARY DISTRIBUTION AS REQUIRED BY CONTRACTOR'S WORK AND SHALL ALLOW EXTENSION OF TRANSFORMER SECONDARY TO OTHER CONSTRUCTION PACKAGE CONTRACTOR TRAILERS.
11. CONTRACTOR PROVIDED TEMPORARY 3-PHASE POWER (MINIMUM CAPACITY OF 150 KVA) FOR CONTRACTOR'S BUILDING CONSTRUCTION AND LAYDOWN AREA USE. TEMPORARY POWER AT THIS OR NEARBY LOCATION SHALL INCLUDE NECESSARY POLE OR PAD MOUNTED TRANSFORMER(S), DISTRIBUTION CENTER AND SECONDARY DISTRIBUTION AS REQUIRED BY CONTRACTOR'S WORK AND SHALL ALLOW EXTENSION OF SECONDARY LINES TO OTHER CONTRACTOR LAYDOWN AND CONSTRUCTION POWER.
12. SEE SHEET G-100005A FOR LOCATION OF LRDR CONSTRUCTION LAYDOWN AND CONTRACTOR OFFICE TRAILERS AREAS.

GENERAL NOTES

1. FOR ELECTRICAL NOTES, LEGEND, AND ABBREVIATIONS, SEE SHEETS E-100001A, E-100002A AND E-100003A.
2. WORK ON THIS SHEET IS TO SHOW GENERAL EXISTING INFRASTRUCTURE AVAILABLE FOR CONTRACTOR'S EXTENSION. CONTRACTOR TO PROVIDE ADDITIONAL OVERHEAD LINES AND POWER TRANSFORMER AS DESCRIBED TO ACCOMMODATE CONTRACTOR TRAILERS AND CONSTRUCTION POWER

[illegible]